



**TRANSMISSION COMPANY NIGERIA (TCN)
PROJECT MANAGEMENT UNIT**

Contracts Awarded by ICB

Name of Project: Nigeria Electricity Transmission Project (NETAP)

Project ID: 61850-NG

Bid/Contract Description: NTP-TR4 Lot 2

Scope of Contract: Supply of Power Equipment to Ojo Stores, Lagos

Duration: 15Months

Contract Signature Date: Not Yet Signed

Awarded Bidder		
Name & Address* of awarded bidder	Bid price at bid opening	Final bid price
Grid Solutions SAS Immeuble le Galilee, 51 Esplande du General, De Gaule 92907, La Defense, Cedex, France.	US\$3,743,044.39 EURO2,640,676.71 NGN19,216,030.00	US\$3,758,313.32 EURO2,651,700.85 NGN19,216,030.00

Evaluated Bidder(s)		
Name of evaluated bidder(s)	Bid price at bid opening	Bid price of evaluated bid
Grid Solution SAS	US\$3,743,044.39 EUR2,640,676.71 NGN19,216,030.00	US\$6,762,400.57
Power System and Automations Solutions Ltd	US\$7,456,260.18	US\$7,456,260.18
AK- AY Elektrik	US\$8,883,462.78	US\$8,460,859.57

Rejected Bidder(s)		
Name of rejected bidder(s)	Bid price at bid opening	Reason(s) for rejection
SHANGHAI ELECTRIC POWER TRANSMISSION & DISTRIBUTION ENGINEERING CO. LTD	US\$7,731,657.90	The Bidder submitted Bid Security in the name of, “Shanghai Electronic Power Transmission & Distribution Engineering Company Limited is different from the name, “Shanghai Electric Power Transmission & Distribution Engineering Co. Ltd” that is in the bid letter,. The bid Security is substantially non responsive.
POWER CHINA GUIZHOU ENGINEERING LTD	US\$8,806,785.17	The Bidder did not sign the Letter of Bid contrary to ITB 20.
FLUOR TECHNICALS	US\$7,881,497.87	The Bidder submitted a Bid Security that is substantially non responsive (ITB 19.4). The Bid security is not in the format included in Section IV of the Bidding document and is valid for 119days against the required validity of 148days. The bid Security submitted is also not subjected to the Uniform Rules for Demand Guarantees (URDG) 2010 Revision, ICC Publication No. 758
COPS Limited	US\$8,602,728.83	The Bidder submitted a Bid Security that is substantially non responsive (ITB 19.4). The Bid security is not in the format included in Section IV of the Bidding document and is valid for 115days against the required validity of 148days. The Bidder did not provide the delivery date/ schedule of the equipment as required in the bidding document.
MBH Power Limited	US\$9,084,286.46	The Bidder has not complied with the technical specifications and requirements of critical supply materials for this project for failing to provide the technical guarantee table for Circuit Breaker, 33kV, 25kA, 1250A.
Xian Electric Engineering Co. Ltd	US\$8,107,357.00	The bidder did not specify the number of operations without

		<p>maintenance of the Circuit breaker being offered, which is meant to provide information on the durability of the Circuit breaker contacts. The Bidder has not complied with the required technical specifications based on the information provided for these items.</p> <p>Xian Electric Engineering Co. LTD has not complied with the technical specifications and requirements of critical supply materials for this project for not complying with the required parameters for Circuit Breaker, 33kV, 25kA, 1250A.</p>
CG Power and Industrial Solution Limited	US\$7,951,357.00	<p>The bidder specified Circuit Breaker's breaking time and closing time of $\leq 70\text{ms}$ and $\leq 80\text{ms}$ respectively as against the required $\leq 40\text{ms}$ and $\leq 50\text{ms}$ respectively. The Evaluation committee views this as a major deviation considering that the 33kV Circuit Breaker is expected to have shorter breaking time than the 132kV Circuit Breaker, that is, to be able to break prior to the 132kV Circuit breaker. In view of this short coming, the bidder has not complied with the specification and requirement for this equipment.</p>

ADDRESS

Transmission Company of Nigeria – Project Management Unit (TCN-PMU)

Engr. Dahiru A. I. - Project Manager (WBP)

No. 10, Kunene Close, Off Bobo Street,

Off Gana Street, Maitama District,

Abuja 900271,

NIGERIA

Tel: +234 8080288802 or +234 8080288803

E-mail: tcnpmu@tcnpmu.ng & dahiru.isyaku@tc.org.ng

Website: www.tcnpmu.ng